



Elliott Duchon, Superintendent

4850 Pedley Road, Jurupa Valley, CA 92509 T 951.360.4100

**SUBJECT: POTABLE WATER SYSTEMS LEAD SAMPLING RESULTS - Mitigation Action
Rubidoux High School - H20-6 Track and Field "C" "R" - B8E2157-06**

On August 1, 2018 Riverside Unified School District Maintenance and Operations Office received verbal notification from AAA LEAD Consultants and Inspections, Inc., indicating that a single sample location at Rubidoux High School had tested above the actionable level upon a first draw sample for lead. The sample location was an exterior drinking fountain located on the East of the Football Stadium, by Gate 2, please see map enclosed.

Jurupa Unified School District Maintenance and Operations performed the following steps to address the subject of notification:

1. 5/29/2018 the Maintenance & Operations Plumbing Staff rendered the fixture inoperable by removing the physical fixture and capping the water supply lines. Work completed within 1.5 hours of receiving verbal notification from AAA LEAD Consultants and Inspections, Inc.
2. 6/1/2018 AAA LEAD Consultants and Inspections, Inc., provided Maintenance & Operations documentation of a sample tested on 5/19/2018 indicating that the water supplies to Rubidoux High School contains 33ppb lead.
3. 9/24/2018 Maintenance & Operations performed follow up testing of the water supply that the replaced bubbler, hoses and angle stops. This was done in order to better define the source of the elevated lead levels.
4. 12/8/2018 AAA LEAD Consultants and Inspections, Inc. verbally contacted Maintenance & Operations to notify the laboratory results "ND".

**ND = Not detected - Analyte NOT DETECTED at or above the Method Detection Limit (if MDL is reported), otherwise at or above the Reportable Detection Limit (RDL)*

**ppb=part per billion*

LEARNING WITHOUT LIMITS

Board of Trustees

Robert Garcia *President*, Silvia Ortega *Clerk*, Karen Bradford, Linda Chard, Melissa Ragole