



Dr. Trenton Hansen, Superintendent

4850 Pedley Road, Jurupa Valley, CA 92509 T (951) 360-4100

Date: May 12, 2022

Re: 21-22-15TEIB Rubidoux H.S. Audio Upgrade Project - Addendum No. 2

TO ALL BIDDERS:

The following changes, omissions, and/or additions to the Bid Documents and/or Project Manual and/or Drawings shall apply to proposals made for and to the execution of the various parts of the work affected thereby, and all other conditions shall remain the same. All parties of interest shall take careful note of the addendum so that the proper allowances may be made in strict accordance with the Addendum.

Bidder shall acknowledge receipt of this addendum in the space provided on the Bid Form. Failure to do so may subject Bidder disqualification.

In case of conflict between Drawings, bid documents and this addendum, this addendum shall govern.

Question: Who will provide connection of audio source to the Stewart amplifier?

Answer: There is a current audio source to the Extron PoleVault amplifier from the ScreenBeam

Question: If the connection is provided by contractor, will the source be from Screenbeam 3.5mm output? Or from the Projector Audio out?

Answer: Contractor will be disconnecting this audio source during the removal of the PoleVault and reconnecting it to the contractor provided and installed Stewart Audio amplifier using the existing cable

Question: Regarding power for the amplifier is there an available power source/plug above the ceiling to use and if not, will that be provided by an electrician?

Answer: Power is existing. If additional receptacles were to be needed, this will be provided by district.

Question: Regarding any fire, life, safety, is there any requirement to mute the system in the case of an emergency/event and if so, will the relay cable be provided by others?

Answer: No. The fire life safety system is substantially louder than the amplifier being installed. If, at a future time, the determination is made that this is needed, it will be installed by the district.

LEARNING WITHOUT LIMITS

Board of Trustees

Melissa Ragole *President*, Robert Garcia *Clerk*, Karen Bradford, M.A., Eric Ditwiler, Ph.D., Joseph Navarro



Dr. Trenton Hansen, Superintendent

4850 Pedley Road, Jurupa Valley, CA 92509 T (951) 360-4100

Question: Will any liquidated damages be waived in the event materials ordered are delayed due to the global supply chain issues?

Answer: No. The district has found that the equipment is readily available. However, the liquidated damages have been decreased to \$500/day. The contract time has been revised to 120 days.

Question: Who will be responsible for the storage of the demoed equipment?

Answer: The contractor will be responsible for moving removed equipment to a secured location/room on campus.

LEARNING WITHOUT LIMITS

Board of Trustees

Melissa Ragole *President*, Robert Garcia *Clerk*, Karen Bradford, M.A., Eric Ditwiler, Ph.D., Joseph Navarro